



## DISTRICT OF NORTH SAANICH

### COUNCIL POLICY

<b>TITLE: WATER SYSTEM – SIZES OF WATER SERVICE</b>	<b>NO. COU-124</b>
<ol style="list-style-type: none"><li>1. Standard Water Service connections are to be 25 mm (1 inch) in size.</li><li>2. Water Service connections larger than 25 mm (1 inch) must be justified by minimum flow requirements and approved by the Director of Infrastructure Services.</li><li>3. Properties designated Class 9 (Agricultural) are authorized to use water for irrigation purposes. A second water service, separate from domestic service, will be permitted on a parcel when utilized for agricultural purposes only.</li></ol>	

<b>EFFECTIVE DATE:</b> 1998	<b>APPROVED BY:</b> COUNCIL	<b>LAST AMENDMENT:</b> 2011	<b>REF:</b>	<b>PAGE 1 of 1</b>
	<b>PREVIOUS POLICY NO.</b> 8001.5			