

DISTRICT OF NORTH SAANICH

COUNCIL POLICY

	TLE: WATER SYSTEM – INSTALLATION OF FIRE /DRANTS	NO. COU-126			
1.	Fire Hydrants within the municipality are not an asset of the Water periphery benefit of a water distribution system.	Utility System but are a			
2.	Fire Hydrants are to be located in new subdivisions at the sole cost of the subdivision developers and shall be located as directed by the Municipal Engineer and in accordance with standards established for fire protection.				
3.	Fire Hydrant locations on existing water distribution lines are to be installed as recommended by the Fire Chief and Municipal Engineer.				
4.	A fire hydrant is to be installed in new subdivisions every 240 metres subject to agreement between the Fire Chief and the Municipal Engineer. Any request for deviation from this standard will be considered by Council. (707/86)				
5.	Out of service fire hydrants shall be covered over with sacking material (1002/87)	for ease of identification.			

EFFECTIVE DATE:		LAST AMENDMENT:	REF:	PAGE 1 of 1
1986	COUNCIL	2011		
	PREVIOUS POLICY NO.			
	8001.7			